

D E S C R I P T I O N

PRODUCT COVERED:

Type TW.

CONSTRUCTION DETAILS:

General - The wire complies with the requirements of the Standard of Underwriters Laboratories Inc., for Thermoplastic-Insulated Wires and Cables.

Insulating Compounds - Recognized Component (R/C) Polymeric Materials for Use in Wire and Cable (QMTT2) PVC insulation compounds for Type TW; or Unlisted Component (QMTT3) PVC Insulation Compound VA-090 (all colors, Column III for temperature correction factor) see File E172950.

OPTIONAL MARKINGS:

"VW-1" for wires employing R/C (QMTT2) PVC insulation compounds rated VW-1, or Unlisted Component (QMTT3) Compound VA-090.

"Oil resistant I" for wires employing R/C (QMTT2) PVC insulation compounds rated oil resistant I, or Unlisted Component (QMTT3) Compound VA-090.

"Gasoline resistant" in addition to the oil resistance marking for wires employing R/C (QMTT2) nylon jacket compounds rated gasoline resistant.

S.H.
T.G.

D E S C R I P T I O N

PRODUCT COVERED:

Type THW.

CONSTRUCTION DETAILS:

General - The wire complies with the requirements in Underwriters Laboratories Inc., Standard for Thermoplastic-Insulated Wires and Cables.

Insulating Compounds - Recognized Component (R/C) Polymeric Materials for Use in Wire and Cable (QMTT2) PVC insulation compounds for Type THW; or Unlisted Component (QMTT3) PVC Insulation Compound VA-090 (all colors, temperature correction factor is Column III), see File E172950.

OPTIONAL MARKINGS:

"VW-1" for wires employing R/C (QMTT2) PVC insulation compounds rated VW-1 or Unlisted Component (QMTT3) Compound VA-090.

"Oil resistant I" or "oil resistant II" for wires employing R/C (QMTT2) PVC insulation compounds rated for the use or Unlisted Component (QMTT3) Compound VA-090.

Wires 250 kcmil and larger employing Unlisted Component (QMTT3) Compound VA-090 may be marked "sunlight-resistant, for CT use" or "sunlight-resistant, for use in cable trays".

S.H.
T.G.

D E S C R I P T I O N

PRODUCT COVERED:

Deep well submersible water pump cable.

CONSTRUCTION DETAILS:

Construction A, without outer covering, only. This cable is constructed in accordance with the Standard for Thermoplastic-Insulated Wires.

